

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-1130:191 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Honeywell International Inc., 1500 West Dundee Road, Arlington Heights, IL 60004
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Models XLS757-1A-C electronic chimes followed by A through Z to indicate product color.
Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 20-24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as chimes for use with separately listed compatible fire alarm control units. For public mode and indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLF: *7135-1591:176 Formerly 7135-1388:200

*Rev. 05-25-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager